



Scott Walker, Governor
Dave Ross, Secretary

October 16, 2015

CUST ID No. 1332792

HUBERT MCQUESTION
LAKE SHORE BURIAL VAULT CO INC
12780 LISBON RD
BROOKFIELD WI 53005

PLAN APPROVAL EXPIRES: 10/31/2020

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.
Product Name: HOLDING TANK -- CAPACITY ADAPTOR (ADDS 1500 GAL. PER ADAPTOR)
(trans id 2623266)
Model Number(s): 7500, 9000 OR 10500 GAL. HOLDING TANK

Product File No: 20150254
BASED ON ONE, TWO OR THREE 1500 GAL. CAPACITY ADAPTORS ADDED
TO 6000 GAL. APPROVED TANK; 96 IN. MAX. DEPTH OF BURY; ADAPTOR
DIMENSIONS (OD) = 230 IN. L X 98 IN. W X 18.25 IN. H]

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2020.**

This approval supersedes the approval issued on 10/5/2010 under product file number 20100375.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- INLET: Standard and optional inlets are located from the top slab at 28 in. from end wall and 20 in. from sidewall.
- TANK CAPACITY ADAPTORS: One, two or three adaptors may be added to the base of the state-approved 6000 gal. (holding) tank. Each tank must be labeled with actual capacity depending on number of capacity adaptors installed.

Identification Numbers
Transaction ID No. 2623266
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

- This product is approved to use the following:
 - Optional two, 4-inch diameter inlets in tank cover.
 - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - See additional stipulations as listed in state-approval for 6,000 gal. (holding) tank.
 - Butyl Sealant on seams, specifically on contacts with tank adaptor and risers, meeting or exceeding ASTM C990.
 - Inlets fitted with Pipe-to-Structure connectors, meeting or exceeding ASTM C923.
 - Bedding: Min. 4-in. washed sand or stone (less than 1 in. size) and min. 8 in. bedding for rock terrain.
 - Backfill: Use same material as bedding when cover is 4 ft. or greater.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspscustomersatisfaction